

1329549

https://www.phoenixcontact.com/gb/products/1329549

Please be informed that the data shown in this PDF document is generated from our Online Catalog. Please find the complete data in the user documentation. Our General Terms of Use for Downloads are valid.



Feed-through terminal block, nom. voltage: 1000 V, nominal current: 57 A, connection method: Push-X-connection, Rated cross section: 10  $\text{mm}^2$ , cross section: 1.5  $\text{mm}^2$  - 16  $\text{mm}^2$ , mounting type: NS 35/7,5, NS 35/15, color: blue

#### Your advantages

- · Fast, powerless conductor connection for all conductor types with the pretensioned contact spring
- · A high level of flexibility when inserting conductors enables conductors with or without ferrules to be connected easily
- · Clear conductor connection with the lateral connection direction and the clear pusher position
- · Easy procurement of information the QR code on the terminal block provides all important information about the product
- Terminal blocks with Push-X connection are part of the COMPLETE line system



1329549

https://www.phoenixcontact.com/gb/products/1329549

### Commercial Data

Item number	1329549
Packing unit	50 pc
Minimum order quantity	50 pc
Sales Key	BE2511
Product Key	BE2511
GTIN	4063151623197
Weight per Piece (including packing)	32 g
Weight per Piece (excluding packing)	32 g
Customs tariff number	85369010
Country of origin	CN



1329549

https://www.phoenixcontact.com/gb/products/1329549

#### **Technical Data**

#### Notes

_			
റം	-	-	
		е	

Note	When establishing a connection on the open housing side of a
	feed-through modular terminal block of the same series and size,
	the block must be provided with a cover if the expected insulation
	voltage is >320 V.

#### Product properties

Product type	Feed-through terminal block		
Number of positions	1		
Area of application	Railway industry		
	Machine building		
	Plant engineering		
Number of connections Number of rows	2		
	1		
Insulation characteristics			
Overvoltage category	III		
Degree of pollution	3		

#### Electrical properties

Test surge voltage	8 kV	

#### Connection data

Number of connections per level	2
Stripping length	17 mm 19 mm
Internal cylindrical gage	A6
Conductor cross section solid	1.5 mm² 16 mm²
Cross section AWG	16 6
Conductor cross section flexible	2.5 mm² 10 mm²
Conductor cross section, flexible [AWG]	14 8
Flexible conductor cross section flexible (ferrule, w/o plastic sleeve)	1.5 mm² 10 mm²
Flexible conductor cross section (ferrule with plastic sleeve)	1.5 mm² 10 mm²
2 conductors with the same cross section, flexible, with TWIN ferrule with plastic sleeve	1.5 mm² 4 mm²
Nominal current	57 A
Maximum load current	70 A (with 16 mm² conductor cross section)
Nominal voltage	1000 V
Nominal cross section	10 mm²

#### Dimensions

Width	10.2 mm
-------	---------



1329549

https://www.phoenixcontact.com/gb/products/1329549

End cover width	2.2 mm
Height	48.8 mm
Height NS 35/15	57.8 mm
Height NS 35/7,5	50.3 mm
Length	72 mm
aterial specifications	
Color	blue
Flammability rating according to UL 94	V0
Insulating material group	ı
Insulating material	PA
echanical properties	
Mechanical data	
Open side panel	Yes
nvironmental and real-life conditions  Needle-flame test	
Time of exposure	30 s
типо от охросите	00.0
Oscillation/broadband noise	
Specification	DIN EN 50155 (VDE 0115-200):2018-05
Spectrum	Service life test category 2, bogie-mounted
	Oct vice life test eategory 2, bogic-mounted
Frequency	f <sub>1</sub> = 5 Hz to f <sub>2</sub> = 250 Hz
Frequency	f <sub>1</sub> = 5 Hz to f <sub>2</sub> = 250 Hz
Frequency ASD level	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ 6.12 (m/s <sup>2</sup> ) <sup>2</sup> /Hz
Frequency ASD level Acceleration	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$
Frequency ASD level Acceleration Test duration per axis	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$
Frequency ASD level Acceleration Test duration per axis Test directions	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$
Frequency ASD level Acceleration Test duration per axis Test directions Shocks	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X-, Y- \text{ and } Z-\text{axis}$
Frequency ASD level Acceleration Test duration per axis Test directions Shocks Specification	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X$ -, Y- and Z-axis
Frequency ASD level Acceleration Test duration per axis Test directions Shocks Specification Pulse shape	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X-, Y- \text{ and } Z-\text{axis}$ DIN EN 50155 (VDE 0115-200):2018-05 Half-sine
Frequency ASD level Acceleration Test duration per axis Test directions Shocks Specification Pulse shape Acceleration	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X-, Y- \text{ and } Z\text{-axis}$ $DIN EN 50155 \text{ (VDE } 0115\text{-}200\text{):}2018\text{-}05$ $Half\text{-sine}$ $30g$
Frequency ASD level Acceleration Test duration per axis Test directions Shocks Specification Pulse shape Acceleration Shock duration	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X-, Y- \text{ and } Z- \text{axis}$ DIN EN 50155 (VDE 0115-200):2018-05  Half-sine $30g$ $18 \text{ ms}$
Frequency ASD level Acceleration Test duration per axis Test directions  Shocks Specification Pulse shape Acceleration Shock duration Number of shocks per direction	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X$ -, Y- and Z-axis  DIN EN 50155 (VDE 0115-200):2018-05 Half-sine $30g$ $18 \text{ ms}$ $3$
Frequency ASD level Acceleration Test duration per axis Test directions  Shocks Specification Pulse shape Acceleration Shock duration Number of shocks per direction Test directions	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X$ -, Y- and Z-axis  DIN EN 50155 (VDE 0115-200):2018-05 Half-sine $30g$ $18 \text{ ms}$ $3$
Frequency ASD level Acceleration Test duration per axis Test directions  Shocks Specification Pulse shape Acceleration Shock duration Number of shocks per direction Test directions  Ambient conditions	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X-, Y- \text{ and } Z-\text{axis}$ DIN EN 50155 (VDE 0115-200):2018-05  Half-sine $30g$ $18 \text{ ms}$ $3$ $X-, Y- \text{ and } Z-\text{axis (pos. and neg.)}$ $-60 ^{\circ}\text{C} \dots 105 ^{\circ}\text{C (max. short-term operating temperature RTI)}$
Frequency ASD level Acceleration Test duration per axis Test directions  Shocks Specification Pulse shape Acceleration Shock duration Number of shocks per direction Test directions  Ambient conditions Ambient temperature (operation)	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X-, Y- \text{ and } Z-\text{axis}$ DIN EN 50155 (VDE 0115-200):2018-05  Half-sine $30g$ $18 \text{ ms}$ $3$ $X-, Y- \text{ and } Z-\text{axis (pos. and neg.)}$ $-60 ^{\circ}\text{C} \dots 105 ^{\circ}\text{C (max. short-term operating temperature RTI Elec.)}$ $-25 ^{\circ}\text{C} \dots 60 ^{\circ}\text{C (for a short time, not exceeding } 24 \text{ h, } -60 ^{\circ}\text{C to}$
Frequency ASD level Acceleration Test duration per axis Test directions  Shocks Specification Pulse shape Acceleration Shock duration Number of shocks per direction Test directions  Ambient conditions Ambient temperature (operation)  Ambient temperature (storage/transport)	$f_1 = 5 \text{ Hz to } f_2 = 250 \text{ Hz}$ $6.12 \text{ (m/s}^2)^2/\text{Hz}$ $3.12g$ $5 \text{ h}$ $X-, Y- \text{ and } Z-\text{axis}$ DIN EN 50155 (VDE 0115-200):2018-05  Half-sine $30g$ $18 \text{ ms}$ $3$ $X-, Y- \text{ and } Z-\text{axis (pos. and neg.)}$ $-60 ^{\circ}\text{C} 105 ^{\circ}\text{C (max. short-term operating temperature RTI Elec.)}$ $-25 ^{\circ}\text{C} 60 ^{\circ}\text{C (for a short time, not exceeding 24 h, -60 ^{\circ}\text{C to +70 ^{\circ}\text{C})}}$



1329549

https://www.phoenixcontact.com/gb/products/1329549

#### Standards and regulations

_	
Connection in acc. with standard	IEC 60947-7-1
Manustina	
Mounting	
Mounting type	NS 35/7,5
	NS 35/15




1329549

https://www.phoenixcontact.com/gb/products/1329549

### Drawings

Circuit diagram





1329549

https://www.phoenixcontact.com/gb/products/1329549

### Approvals

CULus Recognized Approval ID: E60425				
	Nominal Voltage U <sub>N</sub>	Nominal Current I <sub>N</sub>	Cross Section AWG	Cross Section mm <sup>2</sup>
Use group B				
	600 V	55 A	12 - 6	-
Use group C				
	600 V	55 A	12 - 6	-
Use group F				
	1000 V	55 A	12 - 6	-



1329549

https://www.phoenixcontact.com/gb/products/1329549

#### Classifications

_	$\sim$	$\Lambda \cap \cap$

_			
	ECLASS-11.0	27141120	
E	TIM		
	ETIM 8.0	EC000897	
UNSPSC			
	UNSPSC 21.0	39121400	

Phoenix Contact 2022 @ - all rights reserved https://www.phoenixcontact.com

PHOENIX CONTACT Ltd Halesfield 13, Telford Shropshire, TF7 4PG 01952 681700 info@phoenixcontact.co.uk