

PRODUCT-DETAILS

ESB40-40N-01 ESB40-40N-01 Installation Contactor



| Extended Product Type | ESB40-40N-01 |
|------------------------|--|
| Product ID | 1SAE341111M0140 |
| Catalog Description | ESB40-40N-01 Installation Contactor |
| Long Description | The ESB40N installation contactors are used to control single and three-phase loads up to 40 A and can be operated by AC or DC. These contactors are made for use in household applications as well as in industrial environments. The following benefits are provided: Hum-free operation, low power consumption and integrated overvoltage protection. Various contact combinations and accessories are available. |
| Ordering | |
| Package Level 1 EAN | 4013614520075 |
| | |
| Minimum Order Quantity | 4 piece |

Instructions and Manuals 2CDC103043M6801

Dimensions

| 54 mm |
|----------|
| 85 mm |
| 65 mm |
| 0.405 kg |
| |

| Technical | |
|---|--|
| Rated Operational Voltage | Main Circuit 220 V DC Main Circuit 400 V AC |
| Rated Control Circuit Voltage (U _c) | 24 V |
| Rated Frequency (f) | Control Circuit 400 Hz Control Circuit 50 Hz Control Circuit 60 Hz Control Circuit DC Main Circuit 50 Hz Main Circuit 60 Hz Main Circuit DC |
| Rated Operational Current AC-1 (I _e) | (NO) 40 A |
| Rated Operational Current AC-3 (I _e) | (230 V) Single Phase, NO 22 A (400 V) Three Phase, NO 22 A |
| Rated Operational Power AC-1 (P _e) | (230 V) Single Phase, NO 9.2 kW (400 V) Three Phase, NO 27.7 kW |
| Rated Operational Power AC-3 (P _e) | (230 V) Single Phase, NO 3.7 kW (400 V) Three Phase, NO 11 kW |
| Rated Operational Current AC-7a (I _e) | (NO) 40 A |
| Rated Operational Power AC-7a (P _e) | (230 V) Single Phase, NO 9.2 kW (400 V) Three Phase, NO 27.7 kW |
| Rated Operational Current AC-7b (I _e) | (230 V) Single Phase, NO 22 A (400 V) Three Phase, NO 22 A |
| Rated Operational Power AC-7b (P _e) | (230 V) Single Phase, NO 3.7 kW (400 V) Three Phase, NO 11 kW |
| Recommended Screw Driver | Control Circuit Pozidriv 1 Main Circuit Pozidriv 2 |
| Rated Impulse Withstand Voltage (U _{imp}) | 6 kV |
| Rated Insulation Voltage (Ui) | 500 V |
| Connecting Capacity Main Circuit | Flexible with Ferrule 1x 1.5 16 mm ² Flexible with Ferrule 2x 1.5 10 mm ² Flexible with Insulated Ferrule 1x 1.5 16 mm ² Flexible with Insulated Ferrule 2x 1.5 10 mm ² Flexible 1x 1.5 16 mm ² Flexible 2x 1.5 10 mm ² Rigid 1x 1.5 25 mm ² Rigid 2x 1.5 10 mm ² |
| Connecting Capacity Control Circuit | Flexible with Ferrule 1x 0.75 2.5 mm ² Flexible with Ferrule 2x 0.75 1.5 mm ² Flexible with Insulated Ferrule 1x 0.75 2.5 mm ² Flexible with Insulated Ferrule 2x 0.75 1 mm ² Flexible 1x 1 4.0 mm ² Flexible 2x 1 2.5 mm ² Rigid 1x 1 4 mm ² Rigid 2x 1 2.5 mm ² |
| Tightening Torque | Control Circuit 0.9 N·m Main Circuit 2.5 N·m |
| Wire Stripping Length | Control Circuit 7 mm Main Circuit 13 mm |
| Degree of Protection | IP20 |
| Electrical Durability | AC-1 (NO) 150000 cycle AC-3 (NO) 150000 cycle AC-7a (NO) 150000 cycle |

| AC-7b (NO |) 150000 | cycle |
|-----------|----------|-------|
|-----------|----------|-------|

| Mechanical Durability | 1000000 cycle |
|--|--|
| Number of Poles | 4 |
| Number of Auxiliary Contacts NC | 0 |
| Number of Auxiliary Contacts NO | 0 |
| Number of Main Contacts NC | 0 |
| Number of Main Contacts NO | 4 |
| Width in Number of Modular Spacings | 3 |
| Pollution Degree | 3 |
| Standards | IEC/EN 60947-1 IEC/EN 60947-4-1 IEC/EN 61095 UL 60947-1 UL 60947-4-1 |

Technical UL/CSA Main Circuit 480 V AC Maximum Operating Voltage UL/CSA Horsepower Rating (220 ... 240 V AC) Single Phase, NO 3 Hp UL/CSA (220 ... 240 V AC) Three Phase, NO 7.5 Hp (440 ... 480 V AC) Single Phase, NO 7.5 Hp (440 ... 480 V AC) Three Phase, NO 15 Hp **Connecting Capacity** Solid 16-4 AWG Main Circuit UL/CSA Stranded 16-4 AWG Connecting Capacity Solid 16-10 AWG Control Circuit UL/CSA Stranded 16-10 AWG Tightening Torque Control Circuit 8 in·lb UL/CSA Main Circuit 20 in·lb

| Environmental | |
|---|--|
| Ambient Air Temperature | Operation -25 +55 °C Storage -40 +80 °C |
| Maximum Operating Altitude Permissible | 2000 m |
| Resistance to Shock acc. to IEC 60068-2-27 | 11 ms Pulse 15g |
| RoHS Status | Following EU Directive 2011/65/EU |

| Certificates and Declarations (Document Number) | |
|---|--|
| ABS Certificate | 1SAA920000-0101 |
| CB Certificate | 1SAA920005-2001 |
| CQC Certificate | CQC2017010304993562 CQC2017010304993563 |
| cULus Certificate | cUL_E191658 |
| Declaration of Conformity - CCC | 2020980304001310 2020980304001313 |
| Declaration of Conformity - CE | 1SAD938506-0302 |
| Declaration of Conformity - UKCA | 1SAD938501-1302 |
| DNV Certificate | 1SAA920000-0306 |
| EAC Certificate | 1SAA920001-2702 |
| Environmental Information | 1SAC200064H0009 |

| Instructions and Manuals | 2CDC103043M6801 |
|-----------------------------|-----------------|
| NF Certificate | 1SAA920001-1202 |
| RINA Certificate | 1SAA920000-0801 |
| RMRS Certificate | 1SAA920000-0705 |
| RoHS Information | 1SAD938506-0302 |

| Container Information | |
|-----------------------------------|---------------|
| Package Level 1 Units | 4 piece |
| Package Level 1 Width | 88 mm |
| Package Level 1 Height | 69.5 mm |
| Package Level 1 Depth / Length | 222 mm |
| Package Level 1 Gross Weight | 1.62 kg |
| Package Level 1 EAN | 4013614520075 |
| Package Level 2 EAN | 4013614567452 |

| Classifications | |
|---------------------------------------|--|
| Object Classification Code | Q |
| ETIM 5 | EC001653 - Installation contactor for distribution board |
| ETIM 6 | EC001653 - Installation contactor for distribution board |
| ETIM 7 | EC001653 - Installation contactor for distribution board |
| eClass | V11.0 : 27142308 |
| UNSPSC | 39121529 |
| IDEA Granular Category Code (IGCC) | 4759 >> Installation contactor for distribution board |
| ETIM 8 | EC001653 - Installation contactor for distribution board |

Categories

Low Voltage Products and Systems \rightarrow Control Products \rightarrow Contactors \rightarrow Installation Contactors

 ${\sf Low \ Voltage \ Products \ and \ Systems \ \rightarrow \ Modular \ DIN \ Rail \ Products \ \rightarrow \ Command \ and \ Signalling \ Devices \ \rightarrow \ Installation \ Contactors \ And \ A$

