



Certificate of Compliance

This certificate is issued for the following:

Waterflow Alarm Check Valves

Model No	Description	Valve Size		Rated Working Pressure		Remarks
		in	(mm)	psi	(kPa)	
Model B	Alarm Check Valve, Flanged by Flanged	3, 4, 6, 8	(80, 100, 150, 200)	175	(1205)	a, b, c
Model D	Alarm Check Valve, Flanged by Grooved	4, 6, 8	(100, 150, 200)	175	(1205)	a, b, c
Model E	Alarm Check Valve, Grooved by Grooved	4, 6	(100, 150)	175	(1205)	a, b, c

Remarks:

- a. Resilient seat.
- b. With Model E retard chamber
- c. Limited to installations with vertical risers only.

Prepared for:

Rapidrop Global Ltd.
Rutland Business Park, Newark Road
Peterborough PE1 5WA, United Kingdom

FM Approvals Classes: 1041

Approval Identification: 3031630

Approval Granted: February 29, 2008

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

February 2, 2021
Date