

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-S5006

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

Model B, D & E Wet Alarm Valves Wet Alarm Valves

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Rapidrop Global Limited
Rutland Business Park
Newark Road
Peterborough
PE1 5WA
United Kingdom

SS0008

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN12259-2:1999 including amendments A1:2001, A2:2005 & Corrigendum 1:2002

Under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

The constancy of performance of the construction product.

This certificate was first issued on 09 August 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



Sarah Colwell, Director, Fire Suppression Testing and
Certification
On behalf of BRE Global Limited

Date of First Issue: 09 August 2021

Issue Date: 09 August 2021

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
 Bucknalls Lane, Garston, Watford,
 Hertfordshire, UK, WD25 9XX
 Telephone: +44 (0) 333 321 8811
 Fax: +44 (0)1923 664603
 Email: enquiries@breglobal.com
 Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-S5006

Model B, D & E Wet Alarm Valves
 Wet Alarm Valves

Model	Nominal Size (mm)	Maximum Working Pressure (bar)	Orientation
B ⁽¹⁾ ⁽²⁾	80, 100, 150 and 200	12	Vertical
D ⁽¹⁾ ⁽³⁾	100, 150 and 200	12	Vertical
E ⁽¹⁾ ⁽⁴⁾	100, 150 and 200	12	Vertical

Notes:

- (1) With and without Model E retard chamber
- (2) With flanged inlet and flanged outlet.
- (3) With flanged inlet and grooved outlet.
- (4) With grooved inlet and grooved outlet

S. ACowell

Sarah Colwell, Director, Fire Suppression Testing and Certification
 On behalf of BRE Global Limited

Date of First Issue: 09 August 2021
 Issue Date: 09 August 2021
 Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com